



EC DECLARATION OF PERFORMANCE

According to EU Construction Products Regulation No. 305/2011

- 1. Unique Product Identification Code(s): MCP3A – Indoor Call point
- 2. Type Number(s): MCP3A-B[abc][d][e]-[fghi]-[j]k-C – Electrical Triggering Device
MCP3A-Y[abc][d][e]-[fghi]-[j]k-C – Electrical Stop Device
Where:
 - [abc] indicates electrical configuration
 - [d] indicates mounting type: S = surface; F = flush; P = Pattress
 - [e] indicates element type: F = Flexible; G = Glass
 - [fghi] indicates customer reference
 - [j]k indicates other information
- Description: Manual triggering and stop devices
- 3. Intended Use: Fire detection and fire alarm systems installed in and around buildings
- 4. Manufacturer: KAC Alarm Company Limited
KAC House, Thornhill Road,
North Moons Moat,
Redditch, B98 9ND, UK
- 5. Trading Company: KAC Alarm Company Limited
KAC House, Thornhill Road,
North Moons Moat,
Redditch, B98 9ND, UK
- 6. System of assessment: System 1
- 7. Notified Body: Bureau Veritas Iberia S.L.
Notified Body Number: 1035
EC Certificate Number(s): 1035-CPR-ES067290
- 8. European Technical Assessment Reference: Not Applicable
- 9. Declared Performance:

EN 12094-3 Fixed Firefighting systems – Components for gas extinguishing systems – Part 3: Requirements and test methods for manual triggering and stop devices		
Clause	Essential Requirement	Performance
4.1	Electrical Triggering and stop devices	
4.1.1	Electrical Triggering Devices	Not declared
4.1.2	Electrical Stop Devices	Not declared
4.1.3	Other designs	Blue and Yellow type A call points otherwise compliant with EN 54-11. Fitted with lifting cover to ensure dual action operation and prevent accidental activation.
4.2	Non-Electrical Triggering Devices	
4.2.1	General design	n/a - Not declared
4.2.2	Pressure	n/a - Not declared
4.2.3	Strength	n/a - Not declared
4.2.4	Function and ambient temperatures	n/a - Not declared
4.2.5	Operational reliability	n/a - Not declared
4.2.6	Corrosion	n/a - Not declared
4.2.7	Stress corrosion	n/a - Not declared
4.2.8	Vibration	n/a - Not declared
4.2.9	Operating force	n/a - Not declared

- 10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

For and on behalf of: KAC Alarm Company Ltd

Place and date of issue: 08/09/2017

Signature:

Name and Function:

KAC Alarm Company Limited
KAC House
Thornhill Road
North Moons Moat
Redditch
B98 9ND