

BRE Global

Notified Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F2674

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

205-005 Smoke Alarm, 3V, User Replaceable Lithium Battery, Wireless Interconnect

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of:

and produced in the manufacturing plant(s):

**Ambest Electronics (Ningbo) Co. Ltd T/A
Numens
55 Yunhui Road
Yinzhou District
Ningbo, Zhejiang
315137
China**

**Ambest Electronics (Ningbo) Co. Ltd T/A
Numens
55 Yunhui Road
Yinzhou District
Ningbo, Zhejiang
315137
China**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 14604:2005 Smoke Alarms

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 06 December 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 06 December 2019

Date of Issue: 13 February 2020

Issue number 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.



BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F2674

205-005 Smoke Alarm, 3V, User Replaceable Lithium Battery, Wireless Interconnect

Notes:

1. This smoke alarm uses a replaceable battery
2. Battery types approved with this domestic smoke alarm
- Lithium Huiderei CR123A

P Halligan, Certification Manager,
On behalf of BRE Global Limited

Date of First Issue: 06 December 2019

Date of Issue: 13 February 2020

Issue number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.